



OFFICE OF COUNTY MAYOR TIM BURCHETT

Department of Engineering & Public Works • Stormwater Management
205 West Baxter Avenue, Knoxville, TN 37917

Tracking Number: 7009 1410 0000 9455 3567

1/5/11

Allan Smith
P o Box 987
Powell, TN 37849

Notice of Violation

Re: Violation of Knox County's Ordinance for Stormwater Management, O-07-12-101
Dannaher Drive Extension

Dear Mr. Allan Smith,

On January 4, 2011, Mark Parris conducted an inspection of the above referenced location to determine compliance with Knox County's Ordinance for Stormwater Management, O-07-12-101 (henceforth known as Knox County's Stormwater Ordinance). During the site investigation the following violations were observed:

4.3: Sediment controls are failing to retain sediment on site.

- Sections 7.1 and 7.2(b) of Knox County's Stormwater Ordinance specify that EPSC control measures shall be properly installed and maintained in accordance with TDEC's Erosion & Sediment Control Handbook for all land disturbing activities. An inspection of your site on January 4 found your site to be deficient in this area. During a previous rain event on January 1, 2011, erosion controls were not properly installed allowing sediment to leave the site. Sediment has accumulated in the adjacent drainage way at outlet of detention pond #2 and should be removed and stabilized. Necessary erosion controls should be installed immediately to prevent any additional sediment from leaving the site. You are required to rectify the problem immediately in order to avoid further penalties.





OFFICE OF COUNTY MAYOR TIM BURCHETT

Department of Engineering & Public Works • Stormwater Management
205 West Baxter Avenue, Knoxville, TN 37917

Given the facts presented, Knox County is issuing you this Notice of Violation to make you aware of deficiencies at your site in the above listed areas. Please be advised that further penalties may result for each additional day of noncompliance in reference to each of the violations listed above. Under the amended section of Knox County's Stormwater Ordinance, Section 16, violators can be fined up to \$5,000 per day per violation.

I look forward to a timely resolution to this situation. If you have questions regarding this letter, please feel free to contact me at 865-215-5840. You may also contact Knox County Inspector, Mark Parris at 865-215-5308 or mark.parris@knoxcounty.org.

Sincerely,

Christopher Granju, P.E.
Stormwater Management Coordinator
Knox County